

Sprinkler System Alarm Testers

Each separate sprinkler system must be equipped with a separate waterflow alarm. In a high rise building, the system for each floor must be separately alarmed. Where pressure reducing valves are used, a dual alarm and drain piping arrangement is required. The alarm testers listed below combine test and drain valves, a waterflow sight glass, and a calibrated flow orifice in a single assembly to simplify the piping required for such arrangements.

Model A61

Model Designation	Size, inches NPS	Nominal K-factor(s)	Rated working pressure, psi (kPa)	Remarks
A61	1	2.8, 4.2, 5.6, 8.0	300 (2070)	a
A61	1 1/4	2.8, 4.2, 5.6, 8.0, 11.2, 14.0	300 (2070)	a, b
A61	2	4.2, 5.6, 8.0, 11.2, 14.0, 16.8, 22.4, and 25.2	300 (2070)	a, b

Remarks:

- a. Devices supplied with female NPT threaded end connections.
 b. Devices supplied with grooved end connections.

Company Name:	Giacomini SpA
Company Address:	Via per Alzo 39, 28017 San Maurizio d'Opaglio (NO) Italy
Company Website:	http://www.giacomini.com
New/Updated Product Listing:	No
Listing Country:	Italy
Certification Type:	FM Approved