



FlowCon Declaration of Conformity

Pressure Equipment Directive 97/23/EC

Date: May 2014

Manufacturer

FlowCon International ApS, Trafikcenter Allé 17, 4200 Slagelse, Denmark

Description of the pressure equipment

Pressure Independent Control Valve FlowCon Green

Type: Green.0 and Green.1:
A, AB, ABV: DN15/20/25
Green.2:
AB: DN25/32
ABV: DN25/32/40

Fluid Group: 2
Temperature range: -20/+120°C
Design pressure: 25 bar

Conformity assessment followed

DN15/20/25/32 sizes and configurations of the FlowCon Green PICV valve listed above conform to Article 3, Paragraph 3 (Sound Engineering Practice) of the PED Directive 97/23/EU. As such, these valves will not bear the 'CE' marking.
DN040 in the configuration of the FlowCon Green PICV valve listed above conforms to Category I (procedure A).

References of the harmonized Standards

EN 12516 / EN13445 / EN10204-3.1

Authorized on behalf of FlowCon International ApS

Mr. Finn Christensen
Quality and Sourcing Manager