



VSQV.EX3314 Fire Department Connections

[Page Bottom](#)

Fire Department Connections

[See General Information for Fire Department Connections](#)**GIACOMINI SPA**

EX3314

VIA PER ALZO 39

28017 S MAURIZIO D'OPAGLIO, NOVARA ITALY

Exposed type.

Model	Pattern	Size (in.)	Rated Pressure (psig)
A95	Straightway	4 x 2-1/2 x 2-1/2	300
A96	90 Degree	4 x 2-1/2 x 2-1/2	300
A105	Straightway	4 x 2-1/2 x 2-1/2, 6 x 2-1/2 x 2-1/2	175
A106	90 Degree	4 x 2-1/2 x 2-1/2, 6 x 2-1/2 x 2-1/2	175
A105	Straightway	4 x 3 x 3, 6 x 3 x 3	300
A106	90 Degree	4 x 3 x 3, 6 x 3 x 3	300
A90C	Straightway	3 x 2-1/2	300
A90C-1	Straightway	3 x 2-1/2	300
A91C	Straightway	3 x 2-1/2	300
A91C-1	Straightway	3 x 2-1/2	300

Flush type.

Model	Pattern	Size (in.)	Rated Pressure (psig)
A101	Straightway	4 (NPT or Grooved) x 2-1/2 NPT x 2-1/2 NPT, 4 (NPT or Grooved) x 3 NPT x 3 NPT, 6 NPT x 2-1/2 NPT x 2-1/2 NPT, 6 Grooved x 2-1/2 NPT x 2-1/2 NPT	175
A102	90 Degree	4 (NPT or Grooved) x 2-1/2 NPT x 2-1/2 NPT, 4 (NPT or Grooved) x 3 NPT x 3 NPT, 6 NPT x 2-1/2 NPT x 2-1/2 NPT, 6 Grooved x 2-1/2 NPT x 2-1/2 NPT	175
A190T	Single inlet	1-1/2	175
A111	Straightway	6 x 3 x 3 x 3	300
A111	Straightway	6 x 3 x 3 x 3 x 3	300



Trademark and/or Tradename:

[Last Updated on 2016-11-02](#)[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

© 2017 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2017 UL LLC".